



## SPECIFICATION SHEET

Propane			
Property	UNITS	Test Method	Value
Ehtane	Mol%	G.C	0.4 max
Propane	Mol%	G.C	98 min
Butane	Mol%	G.C	1.4 max
Pantanes & Heavir	Mol%	G.C	0.01 max
Copper Corrosion	--	ASTM D-1838	No.1a max
Hydrogen Sulphide	Vol.ppm	ASTM D-2420/Drager	5 max
Sp.Gr@(66/60 OF)	--	ASTM D-2598	To be reported
Sulphur (Volatile)	Wt.ppm	Based on ASTM D-3246	30 max
Vapor Pressure @(100 OF)	Psig	ASTM D-2598	200 max
Water Content	--	ASTM D-2713	Pass

ROYAL  
AGRO ENERGY